Certificate

KIWA-26-DW-10559

Certificate

Issued	30.10.2026	Replaces	-
Valid until	02.07.2031	First issue	-
		Page	1 / 2

Conformity attestation regarding the hygiene suitability for drinking water of a product

Conformity assessment procedure:

☐ Type testing (simplified procedure)

☒ System 1+ with external monitoring

iFIT and INSTAFLEX PB pipes

Product specification see page 2 of the certificate.

Certificate owner:	Uponor GmbH Industriestraße 56 97437 Haßfurt Germany
Manufacturing site(s):	5145 NS, Waalwijk, The Netherlands
Product type:	Single-layer pipe
Product group and conversion factor of the final product(s):	Pipes with ID < 80 mm, Fc = 20 d/dm, M1, according to KTW-BWGL table 8
Regulatory document(s):	Evaluation criteria for plastics and other organic materials in contact with drinking water (27.10.2025)
Temperature range:	☒ cold water 23 °C ☒ warm water 60 °C ☐ hot water 85 °C
Further restrictions:	-

Greven, 30.10.2026

This certificate consists of 2 pages.

DAkkS Deutsche Akkreditierungsstelle D-ZE-11217-01-00

Drinking water hygiene DE-UBA kiwa

i.V. Beatrice Ostermann

- Deputy Head of Certification Body -

KIWA-26-DW-10559

Kiwa GmbH
Gutenbergstr. 29
48268 Greven
Germany

T. +49 (0)2571 9872-0
F. +49 (0)2571 9872-99
info@kiwa.com
kiwa.com

Managing director:
Andreas Müller, Dr. Gero Schönwaßer