

Approval Number 2310567
Test Report: 122300360-0001 & PB2026000457



15th September 2026

Uponor GmbH
Industriestrasse 56,
Hassfurt,
Germany
97437,

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYBUTYLENE

5200

'INSTAFLEX & iFIT'. Grey coloured, extruded PB pipes. For use with water up to 85°C.

APPROVAL NUMBER: 2310567
APPROVAL HOLDER: UPONOR GMBH

The Scheme reserves the right to review approval.
Approval 2310567 is valid between October 2023 and October 2028

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes
WRAS Approvals Manager