

TYPE APPROVAL CERTIFICATE

Certificate No: **TAK00000WH** Revision No: 2

This is to certify:

That the Plastic Piping System, Thermoplastic

with type designation(s)

iFIT-PB PN10 Pipes, iFIT Multilayer PN10 Pipes, iFIT Push-fit fittings

Issued to

Georg Fischer JRG AG

Sissach, BL, Switzerland

is found to comply with

DNV rules for classification - Ships Pt.4 Ch.6 Piping systems

DNV class programme DNV-CP-0072 - Type approval - Thermoplastic piping systems

ISO 21003-2:2008 "Multilayer piping systems for hot and cold water installations inside buildings – Part 2: Pipes"

ISO 21003-3:2008 "Multilayer piping systems for hot and cold water installations inside buildings – Part 3: Fittings"

ISO 21003-5:2008 "Multilayer piping systems for hot and cold water installations inside buildings – Part 5: Fitness for purpose of the system"

ISO 15876-2:2017 "Plastics piping systems for hot and cold water installations – Polybutene (PB) – Part 2: Pipes"

ISO 15876-3:2017 "Plastics piping systems for hot and cold water installations – Polybutene (PB) – Part 3: Fittings"

ISO 15876-5:2017 "Plastics piping systems for hot and cold water installations – Polybutene (PB) – Part 5: Fitness for purpose of the system"

Application:

External pressure rating: 5bar (Collaps pressure: 15 bar).

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Issued at Hamburg on 2023-02-17 This Certificate is valid until 2028-02-16 . DNV local station: Augsburg	
	for DNV
Approval Engineer: Hagen Markus	Sven Klinger Head of Section

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251 Revision: 2021-03 www.dnv.com Page 1 of 6

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.