



INSTITUT PRO TESTOVÁNÍ A CERTIFIKACI, a. s.

třída Tomáše Bati 299, Louky, 763 02 Zlín, Czech Republic
TESTING LABORATORY - TESTING DIVISION

Issues

ATTEST No. 472117695-01

on samples:

Uponor Aqua Pipe 20x2,8 natural
(raw material HDPE Lupolene 5261Z Q456B),
Uponor Aqua Pipe 20x2,8 natural
(raw material HDPE HE1878)

client:

Uponor GMBH PRINCIPAL
Industriestrasse 56, 97437 Hassfurt, Germany
VAT reg. No.: DE133899039

Values obtained and the assessment of the technical parameters:

Evaluated technical parameters of the leaching tests meet hygienic requirements of the article 3 paragraph 2 of the Decree of the Czech Health Ministry No. 409/2005 Coll. *Hygienic requirements for articles intended to come into contact with water and for the water treatment, as amended by the Decree of the Czech Health Ministry No. 446/2021 Coll., for articles intended into the long time contact with drinking water.*

Evaluated sample does not negatively influence the sensorial properties of the drinking water.

This Attest was issued on the basis of following document: ALTR No. 472117695-01 from June 20, 2024, issued by Institut pro testování a certifikaci, a.s. Zlín.

Issued on: June 20, 2024

Valid till: June 30, 2027



Dipl. Ing. Jiří Samsonek, Ph.D.
Head of the testing laboratory

Conditions for use of the Attest and associated information:

1. The Attest applies only to the sample tested by our laboratory.
2. The Attest remains in effect until production technology, initial materials and standards or corresponding regulations are changed; however, its validity will extend beyond the period of its effect.
3. If further requirements of national or EU legal regulations apply to the product, the Attest does not replace procedures and documents necessary for assessment of compliance with these regulations.