

Directory Search Results

WRAS Approval Number: 2203909

Approved Product

Uponor Uni Pipe PLUS system incorporating Uponor RTM metal and PPSU fittings for use with Uni Pipe PLUS PE-RT/AL/PE-RT pipes. Maximum operating pressure 10.0 bar at 70°C.

- **Section:** 1100 Fittings and Pipe - Compatible Systems (?section=1100)
- **WRAS Approval Number:** 2203909
- **Expiry date:** 31/03/2027
- **Size:** 16mm, 20mm & 25mm
- **Marking:** Uponor Uni pipe plus and technical information on pipe. Uponor on fitting.
- **Installation Requirements** R001 (/approvals/testing-requirements/installation_requirements/irn_r001)
- **Model**
 - Uni Pipe PLUS pipes
 - Uponor RTM Fitting Metal
 - Uponor RTM fitting PPSU
- **Manufacturer:** Uponor GmbH [View All Listings by this Company \(?company=14399\)](#)